

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

PV 60174576 0001

Berichtsnummer Report No.:

IN22ORWS 003

Genehmigungsinhaber License Holder:

CW Enerji Mühendislik Ticaret
ve Sanayi A.S.
Antalya OSB 1. Kisim Atatürk Blv.
No:20 Dösemealti
07190 Antalya
Türkiye

Fertigungsstätte Manufacturing Site:

040-0002349884

Prüfzeichen Test Mark:

Geprüft nach Tested according to:

IEC 61215-1:2021
IEC 61215-1-1:2021
IEC 61215-2:2021
IEC 61730-1:2016
IEC 61730-2:2016
EN IEC 61215-1:2021
EN IEC 61215-1-1:2021
EN IEC 61215-2:2021
EN IEC 61730-1:2018
EN IEC 61730-2:2018

Geräteidentifikation
Product Identification
Produkt: PV Module

Product:
Modell: Modelle sind auf nächste(r) Seite(n) gelistet
Type: Type designation(s) are listed on the next page(s)

Technische Daten:
Technical Data:
Gültig bis: 2027-11-20

Date of expiry:
Gültig ab: 2024-01-22

Valid from:
Ausstellungsdatum: 2024-01-22

Date of issue:
Zertifizierungsstelle:
Certification body:


Dipl.-Ing. A. Cox

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

www.tuv.com

 **TÜVRheinland®**
Precisely Right.

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

PV 60174576 0001

Berichtsnummer *Report No.:*

IN22ORWS 003

Produkt *Product:* PV Module

Modell *Type:*

Bezeichnung *Designation:*

Type with monocrystalline half-cut bifacial G12 cells:
CWTxxx-132PMB12 (xxx=645-670 in steps of 1 with 132 cells)

Type with monocrystalline half-cut bifacial M10 cells:
CWTxxx-144PMB10 (xxx=530-560 in steps of 1 with 144 cells)
CWTxxx-132PMB10 (xxx=485-505 in steps of 1 with 132 cells)
CWTxxx-120PMB10 (xxx=440-455 in steps of 1 with 120 cells)
CWTxxx-108PMB10 (xxx=385-400 in steps of 1 with 108 cells)
CWTxxx-108PMBS10 (xxx=390-400 in steps of 1 with 108 cells)

xxx represent output power in Wp

Remarks:

Max. System Voltage: 1500 VDC

Class II acc. to IEC 61140

Max. positive Design Load (downward): 3600 Pa

Max. negative Design Load (upward): 1600 Pa

with safety factor 1.5

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

