### -----客户图 Customer drawings

-----

### CN40-CMMM-01





绝缘材料 Insulation material	PPE
额定电流 Rated current	40A(2.5mm²、4.0mm²、6.0mm²)
额定电压 Rated voltage	1500V(TUV)
测试电压 Test voltage	8kV(50Hz,1min)
连接器接触电阻 Contact resistance	<0.5mΩ
金属导体材料 Contact material	铜,镀锡 Copper, Tin plated
保护等级 Degree of protection	IP2X/IP68
过压等级 Safety class	
阻燃等级 Flame class	UL94-V0
插入力 Insertion force	Max. 50N
拔出力 Withdrawal force	Min. 50N
环境温度范围 Ambient temperature range	-40°C+90°C(IEC/CEI)
适配电缆 Suitable cable cross sections	2.5/4.0/6.0mm <sup>2</sup> AWG14/12/10
连接方式 Connecting system	压接 Crimp conntction

IR

& Slocable	Cable	$\overline{\langle}$
		/

订货料早	零部件料	号 Part P/N	适用电缆规格(Cable Spec)		
Order No.	连 接 器 Connector	端 子 Terminal	导体截面( mm <sup>2</sup> ) Conductor Size	电缆外径( <b>¢</b> D mm) Cable OD	
	公接头 CN40-CMMM-H	公端子 CN40-CM-MT01	$AWG14(2.5mm^2)$		
CIN+0-CM-01	母接头 CN40-CFPM-H	母端子 CN40-CM-FT01	AWG12(4.0mm <sup>2</sup> ) AWG10(6.0mm <sup>2</sup> )	\$4.5~\$8.5	

				尺寸公差	角度公差	核准	万能 2017.12.15	材质		产品	C4 Cable connector	(jo})	Slocahle
				X.0 ±0.25	X.0° ±1°	审核	万能 2017.12.15	表面处理		1 名称   产品	0140 014 01	\/   Donggi	uan Slocable Photovoltaic
A1	2019. 08. 21	额定电流40A	万能	0.X ±0.13	0.X° ±0.5°	设计	万能 2017.12.15	角法 🕀	- ← → 比例	料号	CN40-CM-01	Techno 文世	ology Co., Ltd.
版本	修订日期	修订内容	修订人	0.0X ±0.05	0.0X° ±0.2°	绘图	万能 2017.12.15	页次 1	/4 単位 mm	- <i>~</i> 柔   编号	P-17018	又件   编号	DWG-17018-S01
	1		2		3		4		5		6		7

Ą	I		2		<u> </u>	3		4		I	5		6	客户图 Customer drawings
3					2 2				<u>€ \$1000</u>					
							_(		4		Guide			
No.	<b>BILL</b> 零件编号 P/N	<b>OF MATE</b> 产品名称 Part	RIALS		Q'TY									
No.	<b>BILL</b> 零件编号 P/N P17018-011	OF         MATE           产品名称         Part           C4公接头主体         C4	RIALS Name C4 Male Housing		Q'TY 1	-								
No.	<b>BILL</b> 零件编号 P/N P17018-011 P17018-003	OF     MATE       产品名称 Port     (14)       C4公接头主体     (14)       C4接头电缆防水圈     (14)	RIALS Name C4 Wale Housing C4 Cable Seal Ring		Q'TY 1 2									
No.	<b>BILL</b> 零件编号 P/N P17018-011 P17018-003 P17018-001	OF MATE       产品名称 Part       C4公接头主体       C4接头电缆防水圈       M16*1.5旋帽	RIALS Name C4 Male Housing C4 Cable Seal Ring M16*1.5 Screw Cap		Q'TY 1 2 2							7-2		7-1
No. 1 2 3 4	<b>BILL</b> 零件编号 P/N P17018-011 P17018-003 P17018-001 P17011-110	OF MATE       产品名称 Part       C4公接头主体       C4按头电缆防水圈       M16*1.5旋帽       C4公端子	RIALS Name C4 Male Housing C4 Cable Seal Ring M16*1.5 Screw Cap C4 Male Terminal		Q'TY 1 2 2 1							7-2		7-1
No. 1 2 3 0 4 5	<b>BTLL</b> 零件编号 P/N P17018-011 P17018-003 P17018-001 P17011-110 P17018-004	OF MATE       产品名称 Port       C4公接头主体       C4接头电缆防水圈       M16*1.5旋帽       C4公端子       C4母接头密封圈	RIALS Name C4 Male Housing C4 Cable Seal Ring M16*1.5 Screw Cap C4 Male Terminal C4 Female Conn O Ring	g	Q'TY 1 2 2 1 1 1							7-2		7-1
No. 1 2 3 0 4 5 6	<b>BTLL</b> 零件编号 P/N P17018-011 P17018-003 P17018-001 P17011-110 P17018-004 P17018-021	OF MATE         产品名称 Part         C4公接头主体         C4法表电缆防水圈         M16*1.5旋帽         C4公端子         C4母接头主体	SRIALS Name C4 Male Housing C4 Cable Seal Ring M16*1.5 Screw Cap C4 Male Terminal C4 Female Conn O Ring C4 Female Housing	g	Q'TY 1 2 2 1 1 1 1							7-2		7-1
No. 1 2 3 4 5 6 7-1	BTLL 零件编号 P/N P17018-011 P17018-003 P17018-001 P17011-110 P17018-004 P17018-021 P17011-120	OF MATE         产品名称 Part         C4公接头主体         C4法表电缆防水圈         M16*1.5旋帽         C4公端子         C4母接头密封圈         C4母瑞子         C4母瑞子	RTALS Name C4 Male Housing C4 Cable Seal Ring M16*1.5 Screw Cap C4 Male Terminal C4 Female Conn O Ring C4 Female Housing C4 Female Terminal	ıg	Q'TY 1 2 2 1 1 1 1 1 1							7-2		7-1
No. 1 2 3 4 5 6 7-1 7-2	BTLL 零件编号 P/N P17018-011 P17018-003 P17018-001 P17011-110 P17018-004 P17018-021 P17011-120 P17011-120	OF MATE         产品名称 Port         C4公接头主体         C4法失电缆防水圈         M16*1.5旋帽         C4公端子         C4母接头主体         C4母猫子定位扣	SRIALS Name C4 Male Housing C4 Cable Seal Ring M16*1.5 Screw Cap C4 Male Terminal C4 Female Conn O Ring C4 Female Housing C4 Female Terminal C4 Female Terminal C4 Female Terminal	ıg	Q'TY 1 2 2 1 1 1 1 1 1 1 1 () 1 () 1 () 1 () 1 ()							7-2		7-1
No.       1       2       3       4       5       6       7-1       7-2	BTLよ 零件编号 P/N P17018-001 P17018-003 P17018-001 P17018-001 P17018-004 P17018-021 P17018-021 P17011-120 P17011-120 P17011-105		SRIALS Name C4 Male Housing C4 Cable Seal Ring M16*1.5 Screw Cap C4 Male Terminal C4 Female Conn O Ring C4 Female Housing C4 Female Terminal C4 Female Terminal C4 Female Terminal C5 Female Terminal C6 Female Terminal	ixed buckl	Q'TY 1 2 2 1 1 1 1 1 1 1 2 2 1 1 1 1 1 1 2 2 1 1 1 1 1 1 1 1 1 1 1 1 2	角度公差	核准	万能 2017.12.15	材质			7-2	C4 Cable connector	7-1 To Slocable
$ \begin{array}{c}                                     $	BTLL 零件编号 P/N P17018-011 P17018-003 P17018-001 P17018-001 P17011-110 P17018-021 P17018-021 P17011-120 P17011-120 P17011-105	OF MATE         产品名称 Port         C4公接头主体         C4法接头电缆防水圈         C4法接头电缆防水圈         M16*1.5旋帽         C4公端子         C4母接头密封圈         C4母i         C4         C4	SRIALS Name C4 Male Housing C4 Cable Seal Ring M16*1.5 Screw Cap C4 Male Terminal C4 Female Conn O Ring C4 Female Housing C4 Female Terminal C4 Female Terminal C4 Female Terminal C4 Female Terminal	ig Tixed buckl 尺寸 X.0	Q'TY 1 2 2 1 1 1 1 1 1 2 2 1 1 1 1 1 2 2 1 1 1 1 1 2 2 1 1 1 1 1 1 1 2 2 2 1 1 1 1 2 2 2 1 1 1 2 2 2 1 1 1 2 2 2 1 1 1 2 2 2 1 1 1 2 2 2 1 1 1 2 2 2 1 1 1 1 2 2 2 1 1 1 1 2 2 2 1 1 1 1 2 2 2 1 1 1 1 1 1 2 2 2 1	角度公差 X.0° ±1°	核准	万能 2017.12.15 万能 2017.12.15				7-22 产名产料	C4 Cable connector CN40-CM-01	T SIOCADIA Dongguan Slocable Photovoltaid Technology Co., 1 H.
No. 1 2 3 4 5 6 7–1 7–2 A1 Hz ★	BTLL 零件编号 P/N P17018-001 P17018-003 P17018-001 P17011-110 P17018-004 P17018-021 P17011-120 P17011-120 P17011-105	OF MATE         产品名称 Port         C4公接头主体         C4公接头电缆防水圈         C4公接头电缆防水圈         M16*1.5旋帽         C4公端子         C4公端子         C4母接头密封圈         C4母端子定位扣         C4母端子定位扣         C4母端子定位扣         M         M         C4母端子定位扣         M	SRIALS Name C4 Male Housing C4 Cable Seal Ring M16*1.5 Screw Cap C4 Male Terminal C4 Female Conn 0 Ring C4 Female Housing C4 Female Terminal C4 Female Terminal F: C4 Female Terminal F: C5 Female Terminal F: C5 Female Terminal F: C6 Female Terminal F: C7 Female Terminal F: C4 Female Terminal F: C5 Female Terminal F: C7 Female Te	g Tixed buckl 尺寸 X.0 0.X	Q'TY 1 2 2 1 1 1 1 1 1 2 2 1 1 1 1 1 2 2 1 1 1 1 1 1 2 2 2 1 1 1 1 1 1 2 2 2 1 1 1 1 2 2 2 1 1 1 1 2 2 5 1 1 1 2 2 5 5 5 5	角度公差 X.0° ±1° 0.X° ±0.5°	核 権	万能 2017.12.15 万能 2017.12.15 万能 2017.12.15 万能 2017.12.15	- 材质 表面处理 名法 の			7-22 产名产料专:	C4 Cable connector CN40-CM-01 P-17018	







A4 / 07.17





# CERTIFICATE

No. B 103722 0001 Rev. 00

### Holder of Certificate: Dongguan Slocable Photovoltaic Technology Co., Ltd.

103722

Huawei Scientific Valley NO.1 Xiangshan Road, Dalingshan Town 523812 Dongguan City, Guangdong Province PEOPLE'S REPUBLIC OF CHINA

Production Facility(ies): Certification Mark:



Product:

Connector (Connectors for Photovoltaic System)

Model(s):

CN40-CM, CN40-CM-01, CN40-PM, BC40, BC50

Parameters:	Rated Voltage:	1500 V d.c.
	Rated Current.	40 A
	Protection Class:	11
	Degree of Protection:	IP68 (1m, 1h)
	Ambient Temperature:	-40 °C to +85 °C

Tested according to: IEC 62852(ed.1) EN 62852:2015

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: Valid until: 64290190058601 2024-08-20

horn

Date, 2019-08-21

(Symbol Zhao)



### 

For

**PV** connector

- Model No.:
   CN40-CM-12 \ CN40-CM-01 \ CN40-CM-14 \ CN40-CM-10 \ CN40-CM-8 \ CN40-PM-01 \ CN40-PM-14 \ CN40-PM-12 \ CN40-PM-10 \ BC40-2M1F \ BC40-2F1M \ BC50-3M1F \ BC50-3F1M \ BCY3-2F1M \ BCY3-2M1F \ BCY4-3F1M \ BCY4-3M1F \ BCY5-4F1M \ BCY5-4M1F \ BCY6-5F1M \ BCY6-5M1F \ CN40-FURY
- Applicant : Dongguan Slocable Photovoltaic Technology Co., Ltd.

Floor 4th,Huawei Scientific Valley,Dalingshan Town,Dongguan City,Guangdong Province,China

- Manufacturer : Dongguan Slocable Photovoltaic Technology Co., Ltd. Floor 4th,Huawei Scientific Valley,Dalingshan Town,Dongguan City,Guangdong Province,China
  - Issued By : Shenzhen HTT Technology Co., Ltd.

7F,A Building,Smart valley Science and technology innovation Park,Xixiang,Baoan District,Shenzhen,Guangdong,China

- Tel: 86-755-23595200
- Fax: 86-755-23595201
- Report Number : HTT180607447LR

Issued Date : Jun.28,2018~Jul.03,2018

Date of Report : Jul.03,2018

Note: This report shall not be reproduced except in full, without the written approval of Shenzhen HTT Technology Co., Ltd. This document may be altered or revised by Shenzhen HTT Technology Co., Ltd. personnel only, and shall be noted in the revision section of the document. The test results in the report only apply to the tested sample.



#### TEST REPORT EN 60998-2-2 :2004 Connecting devices for low-voltage circuits for household and similar purposes — Part 2-2: Particular requirements for connecting devices as separate entities with screwless-type clamping units Report reference No. ..... HTT180607447LR Dorrek Wo Keinn Yang Navo Darek Wang Tested by (+ signature)..... Approved by (+ signature) ..... Kevin Yang Date of issue ٠ Jul.03,2018 Shenzhen HTT Technology Co., Ltd. Testing laboratory ..... 7F,A Building,Smart valley Science and technology incovation Location.....: Park, Xixiang, Baoan District, Shenzhen, Guangdong, China Applicant.....: Dongguan Slocable Photovoltaic Technology Co., Ltd. Address:..... Floor 4th, Huawei Scientific Valley, Dalingshan Town, Dongguan City, Guangdong Province, China Manufacturer.....: Dongguan Slocable Photovoltaic Technology Co., Ltd. Address:..... Floor 4th, Huawei Scientific Valley, Dalingshan Town, Dongguan City, Guangdong Province, China Standards..... EN 60998-2-2:2004 Type of test equipment ..... PV connector Trade mark..... N/A CN40-CM-12、CN40-CM-01、CN40-CM-14、CN40-CM-10、 CN40-CM-8、 CN40-PM-01、 CN40-PM-14、 CN40-PM-12、 CN40-PM-10、BC40-2M1F、BC40-2F1M、BC50-3M1F、 Model/Type designation.....: BC50-3F1M、BCY3-2F1M、BCY3-2M1F、BCY4-3F1M、 BCY4-3M1F、BCY5-4F1M、BCY5-4M1F、BCY6-5F1M、 BCY6-5M1F、CN40-FURY Rating..... 1-1500V, 50A



General remarks:	:							
"(see remark #)" re	efers to a remark appended to the	Attachment with:						
report.		1) Photo documentation						
"(see appended ta the report.	ble)" refers to a table appended to	0						
Throughout this re decimal separator.	port a comma is used as the							
The test results pro the object tested.	esented in this report relate only to	to						
This report shall no without the written	ot be reproduced except in full approval of the testing laboratory.	1.						
Unless otherwise s normal conditions the range of 15℃ 1 pressure of 860mb	specified, test are made under at an ambient temperature within to $35^{\circ}$ , RH45% to 75% and an air par of 1060mbar	air						
	V connector							
M	lodel No. CN40-CM-12	12						
(	CE 🖾							
Do	ongguan Slocable Photovoltaic Tech	echnology Co., Ltd.						
Note: Due to simila	Note: Due to similarity of the rating labels, only above label is listed.							



	EN 60998-2-2		
Clause	Requirement – Test	Result	Verdict
	Quantum		
4			
	This clause of Part 1 is applicable.		Р
5	General notes on tests		-
	This clause of Part 1 is applicable except as		Р
	follows:		
5.3	Replacement:		-
	The tests are carried out in the sequence listed		Р
	for each set in Annex AA.		
5.4	Replacement of the first sentence by the		-
	following:		
	The necessary number of new samples to be submitted to the tests are divided into sets as		Р
	detailed in Annex AA and this standard is met if		
	all tests are satisfied.		
6	Main characteristics		-
	This clause of Part 1 is applicable.		Р
7	Classification		-
	This clause of Part 1 is applicable except as		Р
	follows:		
7.101	Classification according to the types of conductors which the terminal can accept		-
7.101.1	Universal terminal		N/A
7.101.2	Non-universal terminal		-
	- terminals for solid conductors ;		Р
	- terminals for rigid conductors;	terminals for solid conductors;	
	- terminals for flexible conductors.		
8	Marking		-
	This clause of Part 1 is applicable except as		Р
	follows:		
8.101	Addition:		-



	EN 60998-2-2		
Clause	Requirement – Test	Result	Verdict
	Non-universal terminals classified according to		Р
	7.101.2 shall be marked as follows:		
	- with the letter(s) "s" or "sol" for terminals		
	declared for solid conductors;		
	- with the letter "r" for terminals declared for rigid		
	conductors;		
	- with the letter "f" for terminals declared for		
	flexible conductors. This marking shall appear where it is practical on the end product or on the smallest package		
	unit or in technical information and/or catalogues.		
8.102	Addition:		-
	An appropriate marking indicating the length of insulation to be removed before insertion of the conductor into the terminal shall be shown on the product or on the smallest package unit or in technical information and/or catalogues.		Р
9	Protection against electric shock		_
	This clause of Part 1 is applicable		N/A
10	Connection of conductors		-
	This clause of Part 1 is applicable except as		Р
	follows:		
10.101	The connection or disconnection of conductors		-
	shall be made- either by the use of a general purpose tool or a convenient device integral with the terminal to open it and to assist the insertion or the withdrawal of the conductors (for		Р
	example, for universal terminals); – or by simple insertion. For the disconnection of the conductors an operation other than a		
	pull on the conductor only shall be necessary (for		
	example, for push-wire terminals).		



	EN 60998-2-2		
Clause	Requirement – Test	Result	Verdict
10.102	Terminals shall accept two or more conductors of the same or of different nominal		Р
	cross-sectional areas or compositions if		
	applicable.		
	Universal terminals shall accept rigid (solid or		
	stranded) and flexible unprepared conductors.		
	Non-universal terminals shall accept the types of		
	conductors declared by the manufacturer. The relationship between the rated connecting capacity of clamping units and connectable		
	conductors as well as data on diameters of		
	conductors are given in Table 101.		
10.103	Each terminal shall accept conductors of cross- sectional areas and types as indicated in Table 101, for the relevant values of the rated connecting capacity. Terminals shall provide, in addition, appropriate connection of at least the two successive smaller crosssectional		Ρ
	areas, for example: a) a terminal having the rated connecting capacity of 1 mm <sup>2</sup> shall clamp reliably a rigid and/or		
	flexible conductor of 0,5 mm <sup>2</sup> , 0,75 mm <sup>2</sup> and 1		
	mm <sup>2</sup> ; b) a terminal having the rated connecting capacity of 10 mm <sup>2</sup> shall clamp reliably rigid		
	conductors of 4 mm <sup>2</sup> , 6 mm <sup>2</sup> and 10 mm <sup>2</sup> and/or		
	flexible conductors of 4 mm <sup>2</sup> and 6 mm <sup>2</sup> . c) a terminal having the rated connecting capacity of 25 mm <sup>2</sup> shall clamp reliably rigid conductors of 10 mm <sup>2</sup> , 16 mm <sup>2</sup> and 25 mm <sup>2</sup> and/or flexible conductors of 6 mm <sup>2</sup> , 10mm <sup>2</sup>		



					EN 60	998-2-2		·
Clause	Require	ment – T	Test				Result	Verdict
Cladoo	rtoquiro		001				Roodit	Voraiot
	and 16 r d) a tern having a shall cla	mm². ninal for a rated c mp relia	flexible onnectir bly flexil	conducto ng capaci ple condu		Р		
	16 mm <sup>2</sup> (Excepti a smalle	and 25 r on: spec er range	mm². cial type: of cross	s of termi -sectiona	nals ma I areas	ay accept as		
	declared	d by the	manufac	cturer.)				
	Table 10	01 – Rat	ed conn	ecting ca	pacity a	and		
	connect	able con	ductors					
	Rated	Conne	ectable conduc	tors and their th Metric	eoretical dian	neters		
	connecting capacity		Rigid		Fle	xible		
	mm²	mm²	Solid ømm	Stranded ømm	mm²	ømm		
	0,2	0,2	0,51	0,53	0,2	0,61		
	0,34	0,34	0,63	0,66	0,34 0,5	0,8		
	0,75	0,75	1,0	1,2	0,75	1,3		
	1,0	1,0 1.5	1,2	1,4	1,0	1,5		
	2,5	2,5	1,9	2,2	2,5	2,3 ª		
	4,0	4,0 6.0	2,4	2,7	4,0 4.0	2,9 a 2 9 a		
	10,0	10,0	3,7	4,2	6,0	3,9		
	16,0	16,0 25.0	4,6	5,3	10,0	5,1		
	35,0	35,0	-	7,9	25,0	7,8		
	C) Text delete NOTE 2 Dian IEC 60228 and	d (C) meters of the la IIEC 60344 (C)	argest rigid and Text deleted (©].	flexible conducto	ors are based	on Table 1 of		
	<sup>a</sup> Dimensions	for Class 5 flexi	ble conductors of	only, according to	IEC 60228A.			
10.104	Complia 10.103 s the follo	nce with shall be o wing tes	the req checked ts:	uirement by inspe	s of 10. ction, a	101 to ind by		Р
10.104.1	The test copper of sectional having the conductor This con shall be diamete diamete New cor for the 5 the 4th i For each pushed shall be obvious. After the damage use.	is carrie conducto al area, in he small or being nection made 5 r conductors th time, nsertion n insertio as far as inserted ese tests d in sucl	ed out or ors of the n accord connect and sub times w ctor and ctor. shall be when th is clamp on, the c s possibl I so that h a way	n three nee e type and lance with then the ted to ead osequent ith the sn 5 times v e used ea e conductor bed at the adequate minal sha as to imp	ew term d the cr n Table largest ch clam disconr nallest with the ch time tor use e same s are ei e termin e conne all not b pair its fi	inals with oss- 101, diameter ping unit. hection largest , except d for place. ther al or ection is e urther		Ρ



	EN 60998-2-2		
Clause	Requirement – Test	Result	Verdict
10.104.2	Three new terminals are fitted with new conductors of the type and of the crosssectional area according to Table 101. Before insertion into the terminal, wires of stranded rigid conductors and flexible conductors shall be reshaped. It shall be possible to fit the conductor into the terminal without undue force in the case of universal terminals and with the force necessary by hand in the case of push-wire terminals. The conductor is either pushed as far as possible into the terminal or has to be inserted so that adequate connection is obvious. After the test, no wire of the conductor shall have escaped outside the terminal.		Ρ
10.105	Three new clamping units are fitted with new conductors of number, cross-sectional area and type (flexible and/or rigid stranded) specified by the manufacturer in the equipment shown in Figure 101. The following tests shall be carried out using new samples for each of the following: a) the conductors of the smallest cross-sectional area; b) the conductors of the largest cross-sectional area. The length of the test conductor shall be 75 mm longer than the height H specified in Table 102. The test conductor is then connected in the clamping unit in the intended manner. The conductor is subjected to the following test: The end of the conductor shall be passed through		Ρ
	an appropriate sized bushing in a platen positioned at a height H below the equipment as given in Table 102. The bushing shall be positioned, in a horizontal plane, such that its centre line describes a circle of 75 mm diameter, concentric with the centre of the clamping unit, in the horizontal plane, the platen is then rotated at a rate of $(10 \pm 2)$ r/min.		



	EN 60998-2-2					
Clause	Requirement -	- Test			Result	Verdict
	1					
	<ul> <li>Interdistance between the mouth of the clamping unit and the upper surface of the bushing shall be within 15 mm of the height in Table 102. The bushing may be lubricated to prevent binding, twisting or rotation of the insulated conductor. A mass, as specified in Table 102, is to be suspended from the end of the conductor. The duration of the test shall be 15 min.</li> <li>NOTE When securing the terminal, care must be taken to avoid exerting excessive force on the terminal which may affect the connection.</li> <li>During the test, the conductor shall neither slip out of the clamping unit, nor break near the clamping unit, nor shall the conductor be damaged in such a way as to render it unfit for further use.</li> <li>Table 102 – Relationship between mass, height and cross-sectional area of conductors</li> </ul>					Ρ
	Conductor cross-section	Diameter of	Height b	Mass for conductor		
		6,4	mm 260	kg 0,2		
	0,34 0,5 0,75 1,0 1,5 2,5 4,0 6,0 10,0 16,0	6,5 6,5 6,5 6,5 9,5 9,5 9,5 9,5 9,5 13,0	260 260 260 280 280 280 280 280 300	0,2 0,3 0,4 0,4 0,7 0,9 1,4 2,0 2,9		
	25,0 35,0	13,0 14,5	300 300	4,5 6,8		
	<ul> <li>a If the bushing hole diameter having the next largest hole size</li> <li>b Tolerance for height: H ± 15</li> </ul>	er is not large enough to a e may be used. imm.	ccommodate the conductor	r without binding, a bushing		
10.106	After the test of 10.105, the pull force given in Table 103 shall be applied to each conductor tested in accordance with 10.105. The force shall be applied in one smooth and continuous application, for 1 min, in the direction of the axis of the conductor. During the test the conductor shall not come out of the terminal.			e given in 10.105. The and he direction he test he terminal.		Ρ
	Table 103 – R	elationship	between pu	ull force and		Р
	Cross-sectional mm <sup>2</sup> 0,2 Pull force 10 E Text deleted C	al area 0,34 0,5 0,75 1,0 15 20 30 35	0 1,5 2,5 4 6 ; 40 50 60 80	10         16         25         35           90         100         135         190		
11	Construction					-
	This clause of	Part 1 is ap	oplicable ex	cept as		Р
ļ	10110103.					



	EN 60998-2-2		
Clause	Requirement – Test	Result	Verdict
11.2	Replacement: Clamping units shall be so designed and constructed that they clamp the conductors		Р
	without undue damage to the conductor. Compliance is checked by inspection and by clauses 10.105 and 10.106. Tests for terminals where the conductor is not clamped between metal surfaces are under consideration.		
11.5	Addition:		-
	Test refers to 15.101.		N/A
	Replacement: NOTE 1 Springs, resilient parts, clamping means, and the like are not considered as parts mainly intended for carrying current. Addition:		-
11.101	Clamping units shall be so designed and constructed that contact pressure shall not be transmitted via insulating material, other than ceramic or pure mica, unless there is sufficient resiliency in the metallic parts, to compensate for any possible shrinkage or yielding of the insulated material. For clamping units for conductors up to and including 0,75 mm <sup>2</sup> , one of the surfaces may be of insulating material other than ceramic or pure mica. The possibility of using material other than metal, as compensation for any possible deformation, for example shrinkage, is under consideration. Compliance is checked by inspection. A test for the efficiency of the resiliency is under consideration.		Ρ
11.102	The insertion and disconnection of the conductors shall be made in accordance with the manufacturer's instructions. Openings for the use of a tool intended to assist the insertion or disconnection shall be clearly distinguishable from the openings intended for the conductor(s). Compliance is checked by inspection.		N/A



	EN 60998-2-2			
Clause	Requirement – Test	Result	Verdict	
11.103	Terminals shall be so designed and constructed that – each conductor is clamped individually; – during the connection or disconnection the conductors can be connected or disconnected either at the same time or separately. It shall be possible to clamp securely any number of conductors up to the maximum provided for. Compliance is checked by inspection and by the tests of 10.105 and 10.106.		Ρ	
11.104	Terminals shall be so designed and constructed that inadequate insertion of the conductor is avoided.		Р	
11.105	Compliance is checked by inspection. Screwless terminals shall be so designed that the connected conductor remains clamped, even when it has been bent during normal installation. NOTE This test is intended to simulate the bending forces on the conductor being transferred to the clamping unit during installation. Compliance is checked by the test of 14 101		Ρ	
12	Resistance to ageing, to humid conditions, to ingress of solid foreign		-	
	This clause of Part 1 is applicable		Р	
13	Insulation resistance and electric strength		-	
	This clause of Part 1 is applicable.		Р	
14	Mechanical strength		-	
	This clause of Part 1 is applicable except as follows:		Р	
14101	For the bending test, three new samples shall be used. The test apparatus, the principle of which is		N/A	
	shown in Figure 103 a), shall be constructed so That – the test conductor, properly inserted into a clamping unit of the connecting devices shall be allowed to be bent (deflected) in all 12 directions each of them differing from the adjacent directions by $30^\circ \pm 5^\circ$ ;		Υ	



EN 60998-2-2					-
Clause	Requirement – Test			Result	Verdict
	<ul> <li>the starting-point of from the original point of from the original point of the original point of the bending of the origination to the testime of force as specified in at a certain distance connecting device. The bending apparate the force is applied perpendicular to the orthe bending is attace conductor within the orthe force for bending in Table 104. The device, including the conductor, if any, to force to the conductor of the ordinate the force to the conductor of the ordinate the orthe orthe bending is attace or the force for bending in Table 104. The device, including the conductor, if any, to force to the conductor or the ordinate the ordin</li></ul>	can be varied by nt. e direction and s conductor from in og positions shall of a suitable dev a Table 104 to the e from the clamp atus shall be so d in the direction e conductor; ained without rol e clamping unit; applied while the rement is made in the conductor istance d shall be extremity of the e guidance for the the point of app or.	y 10° and 20° starting-point its straight II be vice applying a be conductor bing unit of the designed that n tation of the e prescribed a. r is specified be connecting ne blication of the		Ρ
	Cross-section of the test conductor       mm²       ≤0,5       0,75       1,0       1,5       2,5       4       E) Text deleted ©]       * The forces are chosen so that they so	ION TEST TOPCES	Distance d mm 100 100 100 100 100 100 100		
	across the clamping measured when the shown for example The sample is mour test apparatus in su conductor can be fro The surface of the to detrimental contami A clamping unit is fir rigid solid copper co cross-sectional area submitted to a first to clamping unit is sub sequence using the largest cross-section sequence has failed	units under tes conductor is co in Figure 103 b) nted on the fixed ch a way that th eely bent. est conductor sh nation or corros tted as for norm onductor having a specified in 10 est sequence; th mitted to a seco conductor having nal area, unless l.	e voltage drop at can be onnected, as d part of the le test hall be free of ion. al use with a the smallest .103 and is he same ond test ng the the first test		



	EN 60998-2-2				
Clause	Requirement – Test	Result	Verdict		
	The test shall be made with the current flowing (i.e. the current is not switched on and off during the test). A suitable power supply shall be used so that the current variations are kept with ±5 %. A 10th of the test current assigned to the connected conductor, according to Table 2 of Part 1 shall flow through the connecting devices. A bending force shall be applied as shown in Figure 103 a), in one of the 12 directions and the voltage drop across this clamping unit shall be measured. The force shall then be applied successively on each one of the remaining 11 directions shown in Figure 103 a) following the same test procedure. If at any of the 12 test directions the voltage drop is greater then 2,5 mV, the force shall be maintained in this direction until the voltage drop is reduced to a value below 2,5 mV, but for not more than 1 min. After the voltage drop has reached a value below 2,5 mV, the force shall be maintained in the same direction for a further period of 30 s during which period the voltage drop shall not have increased. The other two samples of the test set shall be tested according to the same test procedure, but moving the 12 directions of the force, so that they differ by approximately by 10° for each sample. If one sample has failed at one of the directions of application of the test force, the tests shall be repeated on another set of samples, all of which shall comply with the repeated tests.		Ρ		
15	Temperature rise		-		
	This clause of Part 1 is applicable except as follows:		Р		
15.1	Addition:		-		
	The test shall be made on a set of new samples fitted with new conductors.		Р		



Clause         Requirement – Test         Result         Verdict           15.4         Addition: When the connecting device is designed with clamping units of different rated connecting capacities, the test(s) is(are) made with the current(s) corresponding to the largest size of the conductor to be connected to the part of the terminal having the lowest rated connecting capacity according to the chosen current path. NOTE See Annex CC for examples.         P           15.101         The electrical performance of screwless-type terminals is verified by the following test, which is made on new samples which have not been used for any other test. The test is made with new copper conductors having the minimum and maximum crosssectional areas according to Table 101. – Universal terminals for rigid (solid/stranded) and flexible conductors: six samples for each type of conductor. – Non-universal terminals for solid conductors only: six samples.         P		EN 60998-2-2		
15.4       Addition: When the connecting device is designed with clamping units of different rated connecting capacities, the test(s) is(are) made with the current(s) corresponding to the largest size of the conductor to be connected to the part of the terminal having the lowest rated connecting capacity according to the chosen current path. NOTE See Annex CC for examples.       P         15.101       The electrical performance of screwless-type test, which is made on new samples which have not been used for any other test. The test is made with new copper conductors having the minimum and maximum crosssectional areas according to Table 101. – Universal terminals for rigid (solid/stranded) and flexible conductors: six samples for each type of conductor. – Non-universal terminals for solid conductors only: six samples.       P	Clause	Requirement – Test	Result	Verdict
15.4       Addition: When the connecting device is designed with clamping units of different rated connecting capacities, the test(s) is(are) made with the current(s) corresponding to the largest size of the conductor to be connected to the part of the terminal having the lowest rated connecting capacity according to the chosen current path. NOTE See Annex CC for examples.       P         15.101       The electrical performance of screwless-type terminals is verified by the following test, which is made on new samples which have not been used for any other test. The test is made with new copper conductors having the minimum and maximum crosssectional areas according to Table 101. – Universal terminals for rigid (solid/stranded) and flexible conductors: is samples for each type of conductor. – Non-universal terminals for solid conductors only: six samples.       P	Clause			veraiet
15.101       The electrical performance of screwless-type terminals is verified by the following test, which is made on new samples which have not been used for any other test.       P         The test is made with new copper conductors having the minimum and maximum crosssectional areas according to Table 101.       P         Universal terminals for rigid (solid/stranded) and flexible conductors: six samples for each type of conductor.       P         Non-universal terminals for solid conductors only: six samples.       P	15.4	Addition: When the connecting device is designed with clamping units of different rated connecting capacities, the test(s) is(are) made with the current(s) corresponding to the largest size of the conductor to be connected to the part of the terminal having the lowest rated connecting capacity according to the chosen current path. NOTE See Annex CC for examples.		Ρ
<ul> <li>Non-universal terminals for rigid (solid and stranded) conductors: six samples for each type of conductor.</li> <li>Non-universal terminals for flexible conductors only: six samples.</li> <li>NOTE 1 In case of rigid conductors up to and including 10 mm<sup>2</sup> solid conductors are to be used (for certain crosssectional areas, if solid conductors are not available in a given country, stranded conductors may be used).</li> <li>A conductor having the smallest cross-sectional area is connected as in normal use, to each of three terminals, and a conductor having the largest cross-sectional area is connected as in normal use, to each of three terminals, and a conductor having the largest cross-sectional area is connected in series.</li> <li>NOTE 2 Figure 1 and Figure 2 of Part 1 illustrate how this can be done.</li> <li>The whole test arrangement including the conductors is placed in a heating cabinet which is initially kept at a temperature of 20 °C ± 2 °C.</li> <li>To avoid any movement of the test arrangement until all the following voltage drop tests have been completed it is recommended that the terminals are fixed on a common support</li> </ul>	15.101	The electrical performance of screwless-type terminals is verified by the following test, which is made on new samples which have not been used for any other test. The test is made with new copper conductors having the minimum and maximum crosssectional areas according to Table 101. – Universal terminals for rigid (solid/stranded) and flexible conductors: six samples for each type of conductor. – Non-universal terminals for solid conductors only: six samples. – Non-universal terminals for rigid (solid and stranded) conductors: six samples for each type of conductor. – Non-universal terminals for flexible conductors only: six samples. – Non-universal terminals for flexible conductors only: six samples. NOTE 1 In case of rigid conductors up to and including 10 mm² solid conductors may be used (for certain crosssectional areas, if solid conductors are not available in a given country, stranded conductor may be used). A conductor having the smallest cross-sectional area is connected as in normal use, to each of three terminals, and a conductor having the largest cross-sectional area is connected in series. NOTE 2 Figure 1 and Figure 2 of Part 1 illustrate how this can be done. The whole test arrangement including the conductors is placed in a heating cabinet which is initially kept at a temperature of 20 °C ± 2 °C. To avoid any movement of the test arrangement until all the following voltage drop tests have been completed it is recommended that the terminals are fixed on a common support		P



	EN 60998-2-2				
Clause	Requirement – Test	Result	Verdict		
Clause	Requirement – Test Except for during the cooling period, test current is applied to the circuit. The test current shall be applied for the initial 30 min of each cycle. The test current, established in the series circuit according to the conductor cross-sectional area, is identical to the test current established according to the corresponding rated connecting capacity as defined in Table 2 of Part 1. The terminals shall then be subjected to 192 temperature cycles, each cycle having a duration of approximately 1 h, as follows: The air temperature in the cabinet is raised in approximately 20 min to 40 °C or to the value of the T-marking. It is maintained within $\pm 5$ °C of this value for approximately 10 min. The terminals are then allowed to cool down in approximately 20 min to a temperature of approximately 30 °C forced cooling being allowed. They are kept at this temperature for approximately 10 min and if necessary for measuring the voltage drop, allowed to cool down further, to a temperature of 20 °C $\pm 2$ °C. The maximum allowable voltage drop measured at each clamping unit, at the end of the 192nd cycle, with the current as specified in Table 2 of Part 1 shall not exceed the smaller of	Result	P		
	<ul> <li>either 22,5 mV;</li> <li>or 1,5 times the value measured after the 24th cycle.</li> <li>The measurement shall be made as near as possible to the area of contact on the clamping unit.</li> <li>If the measuring points cannot be positioned closely to the point of contact, the voltage drop within the part of the conductor between the ideal and the actual measuring points shall be deducted from the voltage drop measured.</li> <li>The temperature in the heating cabinet shall be measured at a distance of at least 50 mm from the samples.</li> <li>After this test an inspection with the naked eye, by normal or corrected vision, without additional magnification, shall show no changes evidently impairing further use, such as cracks, deformations or the like.</li> </ul>				
16	Resistance to heat		-		



	EN 60998	-2-2			
Clause	ause Requirement – Test Result				
		1			
	This clause of Part 1 is applicable.		P		
17	Clearances and creepage distances		-		
	This clause of Part 1 is applicable.		N/A		
18	Resistance of insulating material to abnorma	I	-		
	heat and fire				
	This clause of Part 1 is applicable		Р		
19	Resistance of insulating material to tracking		-		
	This clause of Part 1 is applicable.		N/A		
20	EMC requirement		N/A		



#### **Photographs**

Appendix 1 Photo documentation





THE END



Applicant name:	Dongguan Slocable Photovoltaic Technology Co., Ltd.	
Applicant address:	Floor 4th, Huawei Scientific Valley, Dalingshan Town, Dongguan City,	
Applicant additess.	Province,China	

#### Sample information:

Sample Name:	PV connector	
Sample Model:	CN40-CM-12、CN40-CM-01、CN40-CM-14、CN40-CM-10、CN40-CM-8、	
	CN40-PM-01、CN40-PM-14、CN40-PM-12、CN40-PM-10、BC40-2M1F、	
	BC40-2F1M、BC50-3M1F、BC50-3F1M、BCY3-2F1M、BCY3-2M1F、	
	BCY4-3F1M、BCY4-3M1F、BCY5-4F1M、BCY5-4M1F、BCY6-5F1M、	
	BCY6-5M1F、CN40-FURY	
Trade mark :	N/A	
Manufacturer:	Dongguan Slocable Photovoltaic Technology Co., Ltd.	
	Floor 4th,Huawei Scientific Valley,Dalingshan Town,Dongguan City,	
	Guangdong Province, China	
Sample Received Date:	Jun.28,2018	
Testing Period:	Jun.28,2018~Jul.03,2018	
Test Requested	As specified by client, to determine the Lead, Cadmium, Mercury,	
	Hexavalent Chromium, PBBs & PBDEs content in the submitted sample	

RoHS Directive 2011/65/EU Annex II amending Annex (EU)2017/2102

#### **Test Method:**

Tested Item(s)	Test Method	Measured Equipment(s)	MDL
Lead(Pb)	IEC 62321-5:2013 ICP-OES		2mg/kg
Cadmium(Cd)	IEC 62321-5:2013	ICP-OES	2mg/kg
Mercury(Hg)	IEC 62321-4:2013	ICP-OES	2mg/kg
Hexavalent Chromium(Cr(V1))	IEC 62321-7-2:2017	UV-VIS	2mg/kg
Polybrominated Biphenyls (PBBs)	IEC 62321-6:2015 GC-MS		5mg/kg
Polybrominated Dipheny1 Ethers (PBDEs)	IEC 62321-6:2015	GC-MS	5mg/kg

Test Result(s)

Please refer to the following page(s).

James Human sbept chen Inspected by 3 by : Test Kein a Approved by : Date : Jul.03,2018 Technical Manage Report No. HTT180607447CH



Tested Item(s)	Content	Limit	MDL			
Lead(Pb)	N.D.	1000	2			
Cadmium(Cd)	N.D.	100	2			
Mercury(Hg)	N.D.	1000	2			
Hexavalent Chromium(Cr(VI))	N.D.	1000	2			
Polybrominated Biphenyls (PBBs)						
Monobromobiphenyl	N.D.	-	5			
Dibromobiphenyl	N.D.	-	5			
Trbromobiphenyl	N.D.	-	5			
Tetrabromobiphenyl	N.D.	-	5			
Pentbromobiphenyl	N.D.	-	5			
Hexabromobiphenyl	N.D.	-	5			
Heptabromobiphenyl	N.D.	-	5			
Octabromobiphenyl	N.D.	-	5			
Nonabromobiphenyl	N.D.	-	5			
Decabromobiphenyl	N.D.	-	5			
Sum of PBBs	N.D.	1000	-			
Polybrominated Diphenyl Ethers(PBI	DEs)					
Monobromodiphenyl ether	N.D.	-	5			
Dibromodiphenyl ether	N.D.	-	5			
Tribromodiphenyl ether	N.D.	-	5			
Tetrabromodiphenyl ether	N.D.	-	5			
Pentabromodiphenyl ether	N.D.	-	5			
Hexabromodiphenyl ether	N.D.	-	5			
Heptabromodiphenyl ether	N.D.	-	5			
Octabromodiphenyl ether	N.D.	-	5			
Nonabromodiphenyl ether	N.D.	-	5			
Decabromodiphenyl ether	N.D.	-	5			
Sum of PBDES	N.D.	1000	-			

Note: MDL = Method Detection Limit mg/kg = ppm =parts per million N.D. =Not Detected(<MDL)

"-"=Not specified







### Photo(s) of the sample(s)





#### \*\*\* End of report \*\*\*

This report is considered invalidated without the Special Seal for Inspection of the HTT. This report shall not be altered, increased or deleted. The results shown in this test report refer only to the sample(s) tested. Without written approval of HTT, this test report shall not be copied except in full and published as advertisement.