

ATTESTATION of conformity with European Directives

Attestation Number: 1888AB0201N059R1003

Product: SOLAR INVERTER

Brand Name: Huawei

Model: SUN2000-60KTL-M0
Additional Model: SUN2000-50KTL-M0

Applicant: Huawei Technologies Co., Ltd

Address: Administration Building, Headquarters of Huawei Technologies Co., Ltd.,

Bantian, Longgang District, Shenzhen, 518129, P.R.C

Bundan, Longgang Biothot, Chonzhon, Crorzo, Firto				
Parameter	SUN2000-60KTL- M0	SUN2000-50KTL-M0		
MPPT Input	DC 200-1000V, 22A*6 67400W	DC 200-1000V, 22A*6 56200W		
Output	220Vac/380Vac, 230Vac/400Vac, 3(N)W+PE	220Vac/380Vac, 230Vac/400Vac,		
	277Vac/480Vac; 3W+PE,	240Vac/415Vac, 3(N)W+PE,		
	50/60Hz, 60kW	50/60Hz, 50kW		
Max	100A for 380Vac, 95.3A for 400Vac,	83.6A for 380Vac, 79.4A for 400Vac,		
	79.4A for 480Vac, 66kVA	76.6A for 415Vac, 55kVA		
Power	60kW	50kW		
RS485	Support	Support		
PLC	Support	Support		

The submitted sample of the above equipment has been tested for ϵ marking according to following European Directive and standards:

-Electromagnetic Compatibility Directive 2014/30/EU

Standards	Report Number	Report date
EN 61000-6-3:2007 + A1:2011(*) EN 61000-6-4:2007 + A1:2011 EN 61000-3-12:2011 EN 61000-3-11:2000 EN 61000-6-1:2007 EN 61000-6-2:2005	CE180201N059-2R1	Mar. 20, 2018

^{*} The PLC communication mode or AC 480V power supply mode of Solar Inverter is not apply to this standard.

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive.

This verification does not imply assessment of the production of the product. The CE marking may be affixed if all relevant and effective European Directives with CE are applicable.

Supervisor EMC Department



Name: Madison Luo Data: Mar. 20, 2018

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd.

Information given in this document is related to the tested specimen of the described electrical sample.