



**BUREAU  
VERITAS**

# Certificate of compliance

**Applicant:** TommaTech GmbH  
Zeppelinstr. 14  
85748 Garching b.München,  
Germany

**Product:** Photovoltaic inverter

**Model:** Trio Evo 30K,  
Trio Evo 33K,  
Trio Evo 35K,  
Trio Evo 36K

**The device is designed to work as a generation unit of the type: A**

Inverter for single-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

**Applied rules and standards:**

**EN 50549-1:2019/A1:2023**

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

**EN 50549-10:2022**

Requirements for generating plants to be connected in parallel with distribution networks - Part 10: Tests for conformity assessment of generating units

**Compliance with the parameters in Annex C of the standard**  
(see manufacturer's declaration)

**Commission Regulation (EU) 2016/631 of 14 April 2016**

Establishing a network code on requirements for grid connection of generators (NC RFG).  
Type approval for generation units to use in Type A plants.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** CWXK-ESH-P26020668

**Certification Program:** NSOP-0032-DEU-ZE-ES-V11

**Certificate number:** U26-0410

**Date of issue:** 2026-06-03

**Certification body**

**Accreditation**



Domenik Koll  
Head of Energy Systems Germany



Accredited certification body by Deutsche Akkreditierungsstelle GmbH (DAkkS) according to ISO/IEC 17065. The accreditation is valid only for the scope listed in the annex of the accreditation certificate D-ZE-12024-01-00. The Deutsche Akkreditierungsstelle GmbH (DAkkS) is signatory of the multilateral arrangements of EA, ILAC and IAF for mutual recognition.

Without the written consent of Bureau Veritas Consumer Products Services Germany GmbH excerpts of this certificate of conformity shall not be reproduced.



**BUREAU  
VERITAS**

**Annex certificate of conformity No. U26-0410**

**Extract from test report CWXK-ESH-P26020668 issued by a testing laboratory accredited by “Deutsche Akkreditierungsstelle GmbH (DAkkS)” according to ISO/IEC 17025. The accreditation is only valid for the scope listed in the annex of the accreditation certificate “D-PL-12024-03-04”.**

<b>Type Approval and declaration of compliance with the requirements of EN 50549-1 and Commission Regulation (EU) 2016/631 of 14 April 2016</b>				
<b>Manufacturer</b>	TommaTech GmbH Zeppelinstr. 14 85748 Garching b.München, Germany			
<b>Product type</b>	Photovoltaic inverter			
<b>Static converter model</b>	<b>Trio Evo 30K</b>	<b>Trio Evo 33K</b>	<b>Trio Evo 35K</b>	<b>Trio Evo 36K</b>
<b>Input DC (photovoltaic)</b>				
MPP voltage range [V]	200-1000	200-1000	200-1000	200-1000
Max. input voltage [V]	1100	1100	1100	1100
Max. input current per MPPT [A]	2*40	2*40	2*40	2*40
<b>Output AC</b>				
Rated AC voltage [V]	3L/N/PE 400V, 50Hz	3L/N/PE 400V, 50Hz	3L/N/PE 400V, 50Hz	3L/N/PE 400V, 50Hz
Rated output current [A]	43,5	47,8	50,7	52,2
Max. output current [A]	47,9	52,6	55,8	57,4
Nom. converter output (P <sub>NINV</sub> ) [kW]	30	33	35	36
Max. apparent power [kVA]	33	36,3	38,5	39,6



BUREAU  
VERITAS

Annex certificate of conformity No. U26-0410

Extract from test report CWXK-ESH-P26020668 issued by a testing laboratory accredited by "Deutsche Akkreditierungsstelle GmbH (DAkkS)" according to ISO/IEC 17025. The accreditation is only valid for the scope listed in the annex of the accreditation certificate "D-PL-12024-03-04".

Interface protection system and interface switch (Network and system protection "NS-protection")	
Type of protection	integrated NS-protection
Assigned to generation unit type	Trio Evo 30K, Trio Evo 33K, Trio Evo 35K, Trio Evo 36K
Integrated interface switch	Type of switching equipment 1: Relay (Model 117L-1AH1-F-C) Type of switching equipment 2: Relay (Model 117L-1AH2-F-C)
	Note: The output is switched off by the inverter bridge and two relay in series in each line and neutral.
Software	
Firmware version	5412-0324
<b>Note</b> The settings of the product are password protected adjustable. In case the generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration. The above stated generators are tested according to the requirements in the EN 50549-1 and the Commission Regulation (EU) 2016/631 of 14 April 2016. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements.	