

Certificate of Conformity

Product certificate number

No. 230022RECO11-M3-CER

Issued to:

License Holder:

TommaTech GmbH

Angerlweg 14 c/o Kuhlmann, Tomma 85748

Garching b. München, Germany

Trademark:



Contract number:

802595

It is certified that the product:

Type of generating unit: Hybrid inverter

Models		INV-TT-TF- M29.9K	INV-TT-TF- M30K	INV-TT-TF- M35K	INV-TT-TF- M40K	INV-TT-TF- M50K
Technical Data	Nominal power [kW]	29.9	30	35	40	50
	Nominal voltage [V _{ac}]			230 / 400		
	Nominal frequency [Hz]			50 / 60		
	Firmware version			MAIN: Ver 3102		
	Number of phases			Three Phase (3/N/PE)		
	Isolation Transformer			No		

Is in compliance with the standards:

IEC 60068-2-1: 2007. "Environmental testing. Part 2-1. Test Ae: Cold"

IEC 60068-2-2: 2007. "Environmental testing. Part 2-2. Test Be: Dry heat"

IEC 60068-2-14: 2009. "Environmental testing. Part 2-14. Test Na Changes of temperature"

IEC 60068-2-30: 2005. "Environmental testing. Part 2-30. Test Db – Variant 2: Damp heat, cyclic (12 h + 12 h)"

This certificate is based upon the test results of the Test Report n° GZES221102230704 This report confirms that one sample of the above-mentioned products has been tested with positive result against the requirements of these IEC standards for environmental conditions.

The above-mentioned generating unit is certified according to the SGS internal process 4 based on the requirements of the UNE-EN ISO/IEC 17065.

First issued on 23rd January 2024

This certificate is valid until 16th May 2028

Madrid, 23rd January 2024



Daniel Arranz Muñiz
Certification Manager

