

# Certificate of Conformity

By the product certificate number:

No. 230022RECO08-M3-CER

Issued to:

License holder:

**TommaTech GmbH**  
Angerlweg 14 c/o Kuhlmann, Tomma 85748  
Garching b. München, Germany

Trademark:



Contract number:

802595

It is certified that the product:

Type of generating unit: Hybrid inverter

Models:		INV-TT-TF- M29.9K	INV-TT-TF- M30K	INV-TT-TF- M35K	INV-TT-TF- M40K	INV-TT-TF- M50K
Technical Data:	Nominal power [kW]	29.9	30	35	40	50
	Nominal voltage [V <sub>ac</sub> ]			230 / 400		
	Nominal frequency [Hz]			50 / 60		
	Firmware version			MAIN: Ver 3102		
	Number of phases			Three Phase (3/N/PE)		
	Isolation Transformer			No		

Is in compliance with the standard:

**IEC 61727: 2004.** "Photovoltaic (PV) systems – Characteristics of the utility interface."

This certificate is based upon the test results of the Test Report GZES221102230701 <sup>(1)</sup>

<sup>(1)</sup> The tests shown in this test report are carried out at a frequency of 50 Hz and 60 Hz

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-32 based on the requirements of the UNE-EN ISO / IEC 17065.

First issued on 23<sup>rd</sup> January 2024

This certificate is valid until 16<sup>th</sup> May 2028

Madrid, 23<sup>rd</sup> January 2024

Daniel Arranz Muñoz  
Certification Manager



**SGS Tecnos, S.A.U.** C/ Trespaderne, 29 - 28042 Madrid  
This certificate is issued by SGS under its General Conditions for Product Certification at [www.sgs.com/terms and conditions](http://www.sgs.com/terms_and_conditions).  
The status and validity of the certificate can be checked scanning the QR code above included or through the following web [link](#).  
This document cannot be reproduced partially



No. 230022RECO08-M3-CER

Page 1 of 1