



Product Service

# CERTIFICATE

No. Z2 101645 0008 Rev. 02

**Holder of Certificate:** TommaTech GmbH  
Zeppelinstrasse 14  
85748 Garching b. München  
GERMANY

**Certification Mark:**



**Product:** Crystalline Silicon Terrestrial Photovoltaic (PV) Modules  
[Mono Crystalline Silicon Photovoltaic (PV) Module(s)]

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 64290203011214C

**Valid until:** 2029-06-13

**Date,** 2024-07-12

( Billy Qiu )

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT

# CERTIFICATE

No. Z2 101645 0008 Rev. 02

## Model(s):

TTxxx-144PM-HC (xxx=420-465, in steps of 5);  
 TTxxx-132PM-HC (xxx=400-425, in steps of 5);  
 TTxxx-120PM-HC (xxx=350-385, in steps of 5);  
 TTxxx-78PM-HC (xxx=435-460, in steps of 5);  
 TTxxx-72PM-HC (xxx=400-425, in steps of 5);  
 TTxxx-60PM-HC (xxx=330-355, in steps of 5).  
 TTxxx-144PM10 (xxx=525-560, in steps of 5);  
 TTxxx-132PM10 (xxx=480-515, in steps of 5);  
 TTxxx-120PM10 (xxx=440-465, in steps of 5);  
 TTxxx-108PM0 (xxx=390-420, in steps of 5).  
 TTxxx-132PM12 (xxx=640-675, in steps of 5);  
 TTxxx-120PM12 (xxx=580-615, in steps of 5);  
 TTxxx-108PM12 (xxx=520-550, in steps of 5).  
 TTxxx-132PM12H (xxx=670-700, in steps of 5);  
 TTxxx-120PM12H (xxx=610-635, in steps of 5);  
 TTxxx-108PM12H (xxx=545-570, in steps of 5).  
 TTxxx-144TN10 (xxx=555-605, in steps of 5);  
 TTxxx-132TN10 (xxx=510-555, in steps of 5);  
 TTxxx-120TN10 (xxx=460-505, in steps of 5);  
 TTxxx-108TN10 (xxx=415-455, in steps of 5).

xxx stands for rated output power at STC.

## Parameters:

Protection class:	Class II
Max. system voltage:	1500 V d.c.
Fire safety class:	Class C according to UL 790
Construction:	Framed, with Junction box, Cable and Connectors

## Tested according to:

IEC 61215-1:2016  
 IEC 61215-1-1:2016  
 IEC 61215-2:2016  
 IEC 61730-1:2016  
 EN IEC 61730-1:2018  
 IEC 61730-2:2016  
 EN IEC 61730-2:2018