

# Certificate of compliance

**Applicant:** TommaTech GmbH  
Zeppelinstr. 14 - 85748 Garching b.München  
Germany

**Product:** Photovoltaic inverter

**Model:** Uno-A-3.0-N, Uno-A-2.5-N,  
Uno-A-2.0-N, Uno-A-1.5-N,  
Uno-A-1.0-N

The device is designed to work as a generation unit of the type: **A**

Inverter for single-phase parallel connection to the public grid. The network monitoring and disconnection device is an integral part of the above-mentioned model.

**Applied rules and standards:**

**EN 50549-1:2019**

Requirements for parallel connection of installations with distribution networks - Part 1: Connection to an LV distribution network - Production of installations up to and including Type B

- 4.4 Normal operating range
- 4.5 Immunity to disturbances
- 4.6 Active response to frequency deviation
- 4.7 Power response to voltage variations and voltage changes
- 4.8 EMC and power quality
- 4.9 Interface protection
- 4.10 Connection and starting to generate electrical power
- 4.11 Ceasing and reduction of active power on set point
- 4.13 Requirements regarding single fault tolerance of interface protection system and interface switch

**DIN VDE V 0124-100:2020 (5.5.2.1 Functional safety of network and system protection)**

Grid integration of generator plants - Low-voltage - Test requirements for generator units to be connected to and operated in parallel with low-voltage distribution networks

**Commission Regulation (EU) 2016/631 of 14 April 2016**

Establishing a network code on requirements for grid connection of generators (NC RFG).  
Type approval for generation units to use in Type A plants.

At the time of issue of this certificate, the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** ASUE-ESH-P24112200

**Certificate number:** U24-1182

**Certification Program:** NSOP-0032-DEU-ZE-V10

**Date of issue:** 2024-12-06

**Accreditation**

